



TERM END

NOTES:

1. CONDUIT BOX CAN BE ROTATED IN 90 ° STEPS.
2. CONDUIT BOX CAN BE MOUNTED IN OPPOSITE SIDE BY REMOVING BRACKETS AND TURNING FRAME 180 °. THIS MODIFICATION CAN BE PERFORMED ONLY BY THE ORIGINAL EQUIPMENT MANUFACTURER, OR BY A FACILITY THAT IS COVERED UNDER UNDERWRITERS LABORATORIES INC. CATEGORY PTKQ, TITLED "MOTOR AND GENERATORS, REBUILT FOR USE IN HAZARDOUS LOCATION".
3. NAMEPLATE TO BE READ FROM CONDUIT BOX SIDE OF MOTOR.

| | | | | | | | |
|------|---------|-------|-------|----|-----|-----|-------|
| 1212 | 213/215 | 23.45 | 11.76 | 10 | 7 | 5 | 20.11 |
| 912 | 213/215 | 20.45 | 8.63 | 7 | 5.5 | 3.5 | 17.11 |
| DASH | FRAME | C | B | 2F | 2FF | BS | AG |

| | | | | | | | | | |
|--|-----------------------|-----------------------------|-----------|--------|-------------|---------------------------------------|----------|-------------------|------------|
| | | TOLERANCES UNLESS SPECIFIED | | LEESON | | ELECTRIC MOTORS GEARMOTORS AND DRIVES | | DRAWN PN 9/2/2010 | |
| | | DEC INCHES | | | | | | CHK AK 9/2/2010 | |
| | | .X ±.1 | | | | | | APPR | |
| | | .XX ±.02 | | | | TITLE OUTLINE | | SCALE 1:4 | |
| | | .XXX ±.005 | | | | 210.FR - EPFC | | REF 037660 | |
| 01 | UPDATED PER IS12-0462 | GR | 2/14/2012 | PN | XXXX ±.0005 | MATL | | FMF | |
| NO | REVISION | BY & DATE | CHK | ANG | ±730" | FINISH | | PREV | |
| THIS DRAWING IN DESIGN AND DETAIL IS OUR PROPERTY AND MUST NOT BE USED EXCEPT IN CONNECTION WITH OUR WORK. ALL RIGHTS OF DESIGN AND INVENTION ARE RESERVED. THIS IS AN ELECTRONICALLY GENERATED DOCUMENT - DO NOT SCALE THIS PRINT | | | | | | RFP | CAD FILE | SIZE | DRAWING NO |
| | | | | | | DIST | 037702LE | B | 037702LE |
| | | | | | | | | | REV 01 |